



ARCHER RUBBER LLC  
 213 CENTRAL STREET  
 MILFORD, MA 01757-3458  
 TEL: (508) 473-1870  
 FAX: (508) 478-7078  
[www.archerrubber.com](http://www.archerrubber.com)  
[sales@archerrubber.com](mailto:sales@archerrubber.com)

*Engineered Coated Fabrics*

STYLE# 2236

DESCRIPTION / CONSTRUCTION

D/C MAROON NITRILE ON COTTON

AREAS OF APPLICATIONS

ELECTRICAL BLANKETS

"Material conform to electrical requirements of ASTM-D-1048 @ 2500 Volts AC RMS for 60 seconds."

CHARACTERISTICS / PHYSICAL PROPERTIES

TEST / METHOD	Federal Standard 191A or ASTM	REQUIREMENT
FINISHED WEIGHT	Fed. Std. 191A METHOD 5041	23.0 TO 29.0 OZ/SQ YD
FINISHED THICKNESS GAUGE	METHOD ASTM D1777	0.023" MIN. TO 0.027" MAX.
FINISHED WIDTH USABLE		36 INCHES
MULLEN BURST RESISTANCE	METHOD ASTM D751	70 PSI MINIMUM
COATING ADHESION	Fed. Std. 191A METHOD 5970	NO REQUIREMENT
BREAKING STRENGTH	Fed. Std. 191A METHOD 5100	WARP 75 LBS MIN FILL 75 LBS MIN
TEMPERATURE RANGE		-20° F TO 200° F

The information contained herein was developed in our laboratories and is believed reliable. It is offered in good faith. However, as prospective users conditions and methods of use are beyond our control, we recommend the user determine the suitability of this product before adapting our materials on a commercial scale.